

MUNICIPAL CORPORATION OF DELHI PUBLIC HEALTH DEPARTMENT : SOUTH ZONE SRI AUROBINDO MARG, GREEN PARK, NEW DELHI-110016

dhosouthzone@gmail.com

No: DHO/SZ/2023/ D 866

Dated ...

Name of the School: St. Mary's Public School

School Address: 532A, Forest Lane, Neb Sarai, New Delhi

3. No. of Shift: Morning Timing: 07.20AM to 1:00PM

Total: 1007 4. No. of Students: Boys: 549 Girls: 458

Total: 45 Female: 32 Male: 13 5. No. of Staffs:

Details of Accommodations present in School

1. Floor Space in the Classroom Sufficient/insufficient: Sufficient

2. The Classrooms are Well Lighted/ ill lighted: Well Lighted

3. The Classrooms are Well Ventilated/ ill ventilated: Well Ventilated

4. The Classrooms are kept / Not kept Neat & Clean: Neat & Clean

5. The Classrooms/Building requires/ do not required Whitewash etc: Not required

6. The Drinking Water is Wholesome/ not wholesome: Wholesome

7. The Latrine arrangement is Sanitary/ insanitary: Sanitary condition from health point of view.

No. of toilets seats for student

- 1. One latrine-cum-urinal is required for 25 female student, so total is sufficient.
- One latrine for 40 male student is required so total is sufficient
- 3. Separate Toilet arrangement for staff present: Yes/No Yes exist separate for staff
- 4. The Overall facilities: Good/ Adequate/Inadequate: Adequate from health point of view & valid upto one year from issuance date.

If Building Department or any other Govt. agency takes actions against u/a constructions or any dispute, then the Health Certificate will be stand cancelled/revoked without any further intimation in this regard.

> Deputy Health Officer South Zone

Dr. Deepak Mittal Dy. Health Officer/SZ

(Remarks: Certificate is valid for one year)